

SIX-MONTH STUDY - VERY OLD BATTERIES

Specific Gravity Readings

Batteries 38 and 40 went in service in 2009; 45,52 and 55 in 2010 Battery 61 came from Idaho. It was also 7-8 years old

These batteries were to be discarded

The batteries averaged **1.221**

Final readings averaged **1.270**

Batteries were returned to service

